

Pulse Oximeter Service (PLXS)

Bluetooth® Implementation Conformance Statement (ICS) Proforma

- **Revision:** PLXS.ICS.p4
- **Revision Date:** 2026-02-17
- **Prepared By:** Medical Devices Working Group
- **Published during TCRL:** TCRL.pkg102



This document, regardless of its title or content, is not a Bluetooth Specification as defined in the Bluetooth Patent/Copyright License Agreement (“PCLA”) and Bluetooth Trademark License Agreement. Use of this document by members of Bluetooth SIG is governed by the membership and other related agreements between Bluetooth SIG Inc. (“Bluetooth SIG”) and its members, including the PCLA and other agreements posted on Bluetooth SIG’s website located at www.bluetooth.com.

THIS DOCUMENT IS PROVIDED “AS IS” AND BLUETOOTH SIG, ITS MEMBERS, AND THEIR AFFILIATES MAKE NO REPRESENTATIONS OR WARRANTIES AND DISCLAIM ALL WARRANTIES, EXPRESS OR IMPLIED, INCLUDING ANY WARRANTY OF MERCHANTABILITY, TITLE, NON-INFRINGEMENT, FITNESS FOR ANY PARTICULAR PURPOSE, THAT THE CONTENT OF THIS DOCUMENT IS FREE OF ERRORS.

TO THE EXTENT NOT PROHIBITED BY LAW, BLUETOOTH SIG, ITS MEMBERS, AND THEIR AFFILIATES DISCLAIM ALL LIABILITY ARISING OUT OF OR RELATING TO USE OF THIS DOCUMENT AND ANY INFORMATION CONTAINED IN THIS DOCUMENT, INCLUDING LOST REVENUE, PROFITS, DATA OR PROGRAMS, OR BUSINESS INTERRUPTION, OR FOR SPECIAL, INDIRECT, CONSEQUENTIAL, INCIDENTAL OR PUNITIVE DAMAGES, HOWEVER CAUSED AND REGARDLESS OF THE THEORY OF LIABILITY, AND EVEN IF BLUETOOTH SIG, ITS MEMBERS, OR THEIR AFFILIATES HAVE BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES.

This document is proprietary to Bluetooth SIG. This document may contain or cover subject matter that is intellectual property of Bluetooth SIG and its members. The furnishing of this document does not grant any license to any intellectual property of Bluetooth SIG or its members.

This document is subject to change without notice.

Copyright © 2014–2026 by Bluetooth SIG, Inc. The Bluetooth word mark and logos are owned by Bluetooth SIG, Inc. Other third-party brands and names are the property of their respective owners.



Contents

1	General principles	4
1.1	Implementation Under Test (IUT) identification	4
1.2	Enforcement of inter-layer dependencies	4
2	ICS declarations	5
2.1	Versions	5
2.2	Transports	5
2.3	Service and feature requirements	5
2.4	GATT requirements	8
2.5	SDP requirements	9
3	References	10
4	Revision history and acknowledgments	11



1 General principles

1.1 Implementation Under Test (IUT) identification

Using the Bluetooth SIG qualification tool, the implementer is expected to declare details about what will be implemented.

1.2 Enforcement of inter-layer dependencies

This ICS includes one or more tables with inter-layer dependencies (ILDs). ILDs are used for specification requirements that are dependent on other supporting specifications. ILDs can refer to an individual ICS item in a separate layer (individual ILD), or it can refer to the full layer (full-layer ILD).

ILDs residing in an X2Core layer will be enforced from the Bluetooth SIG qualification tool in the following conditions, depending on where the referred ILD is residing:

Referred ILD resides in	Individual ILD	Full-layer ILD
Controller layer	Core-Complete configuration, or Referred layer is supported	N/A
Lower HCI layer	HCI is supported	N/A
Upper HCI layer	Core-Host configuration, or UHCI is supported	N/A
Host layer	Core-Host configuration, or Core-Complete configuration, or Referred layer is supported	N/A
X2Core layer	Core-Host configuration, or Core-Complete configuration, or Referred layer is supported	Core-Host configuration, or Core-Complete configuration

Table 1.1: Enforcement of an ILD within the Bluetooth SIG qualification tool

2 ICS declarations

2.1 Versions

Table 0: X.Y Versions

Item	Version	Reference	Status
1	PLXS v1.0	[1]	C.1, C.2

C.1: Mandatory.

C.2: Can only be supported with an active X.Y.Z version after Deprecation or Withdrawal. Deprecated 2023-02-01. Withdrawn 2025-02-01.

Table 0a: X.Y.Z Versions

Item	Version	Reference	Status
1	PLXS v1.0.1	[3]	C.1

C.1: Mandatory IF PLXS 0/1 “PLXS v1.0”, otherwise Excluded.

2.2 Transports

Table 1: Transport Requirements

Item	Transport	Reference	Status
1	Service supported over BR/EDR	[1] 1.5	C.1, C.3
2	Service supported over LE	[1] 1.5	C.2, C.3

C.1: Excluded for this Service IF CORE 41/2 “LE Core Configuration” OR CORE 40/1 “Core-Controller”.

C.2: Excluded for this Service IF CORE 41/1 “BR/EDR Core Configuration” OR CORE 40/1 “Core-Controller”.

C.3: Mandatory to support at least one.

2.3 Service and feature requirements

Table 2: Feature Requirements

Item	Capability	Reference	Status
1	Measurement Status Support	[1] 3.3.1.1	O
2	Device and Sensor Status Support	[1] 3.3.1.1	O
3	Measurement Storage for Spot-check Measurement Support	[1] 3.3.1.1	O
4	Timestamp for Spot-check measurements is supported	[1] 3.3.1.1	C.1
5	SpO2PR-Fast Metric Supported	[1] 3.3.1.1	O
6	SpO2PR-Slow Metric Supported	[1] 3.3.1.1	O
7	Pulse Amplitude Index Supported	[1] 3.3.1.1	O
8	Multiple Bond Supported	[1] 3.3.1.1	O
9	Indications for changes of supported features	[3] 3, 3.3.1	M

C.1: Mandatory IF PLXS 2/3 “Measurement Storage for Spot-check Measurement Support”, otherwise Optional.



Table 3: Service Requirements

Item	Capability	Reference	Status
1	Pulse Oximeter Service	[1] 2	M
2	PLX Spot-check Measurement Characteristic	[1] 3.1	C.1
3	Flags field (PLX Spot-check Measurement Characteristic)	[1] 3.1.1.1	C.2
4	SpO2PR-Spot-Check field (PLX Spot-check Measurement Characteristic)	[1] 3.1.1.2	C.2
5	Timestamp field (PLX Spot-check Measurement Characteristic)	[1] 3.1.1.3	C.3
6	Measurement Status field (PLX Spot-check Measurement Characteristic)	[1] 3.1.1.4	C.4
7	Device and Sensor Status field (PLX Spot-check Measurement Characteristic)	[1] 3.1.1.5	C.11
8	Pulse Amplitude Index (PLX Spot-check Measurement Characteristic)	[1] 3.1.1.6	C.6
9	PLX Continuous Measurement Characteristic	[1] 3.2	C.1
10	Flags field (PLX Continuous Measurement Characteristic)	[1] 3.2.1.1	C.7
11	SpO2PR-Normal field (PLX Continuous Measurement Characteristic)	[1] 3.2.1.2	C.7
12	SpO2PR-Fast field (PLX Continuous Measurement Characteristic)	[1] 3.2.1.3	C.8
13	SpO2PR-Slow field (PLX Continuous Measurement Characteristic)	[1] 3.2.1.4	C.9
14	Measurement Status field (PLX Continuous Measurement Characteristic)	[1] 3.2.1.5	C.4
15	Device and Sensor Status field (PLX Continuous Measurement Characteristic)	[1] 3.2.1.6	C.12
16	Pulse Amplitude Index field (PLX Continuous Measurement Characteristic)	[1] 3.2.1.7	C.6
17	PLX Features Characteristic	[1] 3.3	M
18	Supported Features field (PLX Features Characteristic)	[1] 3.3.1.1	M
19	Measurement Status field (PLX Features Characteristic)	[1] 3.3.1.2	C.4
20	Device and Sensor Status field (PLX Features Characteristic)	[1] 3.3.1.3	C.5
21	Record Access Control Point (RACP) Characteristic	[1] 3.4	C.3
22	Report Stored Records Op Code	[1] 3.4.4	C.10
23	Delete Stored Records Op Code	[1] 3.4.5	O
24	Abort Operation Op Code	[1] 3.4.6	O
25	Report Number of Stored Records Op Code	[1] 3.4.7	O
26	Number of Stored Records Response Op Code	[1] 3.4.7	O
27	Response Code Op Code (RACP)	[1] 3.4.4–3.4.8	C.10

C.1: Mandatory to support at least one.

C.2: Mandatory IF PLXS 3/2 “PLX Spot-check Measurement Characteristic”, otherwise Excluded.

C.3: Mandatory IF PLXS 2/3 “Measurement Storage for Spot-check Measurement Support”, otherwise Optional.



- C.4: Mandatory IF PLXS 2/1 “Measurement Status Support”, otherwise Excluded.
- C.5: Mandatory IF PLXS 2/2 “Device and Sensor Status Support”, otherwise Excluded.
- C.6: Mandatory IF PLXS 2/7 “Pulse Amplitude Index Supported”, otherwise Excluded.
- C.7: Mandatory IF PLXS 3/9 “PLX Continuous Measurement Characteristic”, otherwise Excluded.
- C.8: Mandatory IF PLXS 2/5 “SpO2PR-Fast Metric Supported”, otherwise Excluded.
- C.9: Mandatory IF PLXS 2/6 “SpO2PR-Slow Metric Supported”, otherwise Excluded.
- C.10: Mandatory IF PLXS 3/21 “Record Access Control Point (RACP) Characteristic”, otherwise Excluded.
- C.11: Mandatory IF PLXS 2/2 “Device and Sensor Status Support” AND PLXS 3/2 “PLX Spot-check Measurement Characteristic”, otherwise Excluded.
- C.12: Mandatory IF PLXS 2/2 “Device and Sensor Status Support” AND PLXS 3/9 “PLX Continuous Measurement Characteristic”, otherwise Excluded.

Table 3a: Indications for changes of supported features

Prerequisite: PLXS 2/9 “Indications for changes of supported features”

Item	Capability	Reference	Status
1	Changeable PLX Features	[3] 3	O
2	PLX Features characteristic indication	[3] 3, 3.3.1	C.1

- C.1: Mandatory IF PLXS 3a/1 “Changeable PLX Features”, otherwise Excluded.

Table 4: Report Stored Records Filter Parameters

Prerequisite: PLXS 3/22 “Report Stored Records Op Code”

Item	Feature	Reference	Status
1	All Records Operator	[1] 3.4.4	M

Table 5: Delete Stored Records Filter Parameters

Prerequisite: PLXS 3/23 “Delete Stored Records Op Code”

Item	Feature	Reference	Status
1	All Records Operator	[1] 3.4.5	O

Table 6: Abort Operation Filter Parameters

Prerequisite: PLXS 3/24 “Abort Operation Op Code”

Item	Feature	Reference	Status
1	Null Operator	[1] 3.4.6	O



Table 7: Report Number of Stored Records Filter Parameters*Prerequisite: PLXS 3/25 “Report Number of Stored Records Op Code”*

Item	Feature	Reference	Status
1	All Records Operator	[1] 3.4.7	O

Table 8: Number of Stored Records Response Filter Parameters*Prerequisite: PLXS 3/26 “Number of Stored Records Response Op Code”*

Item	Feature	Reference	Status
1	Null Operator	[1] 3.4.7	M

Table 9: Response Code Filter Parameters*Prerequisite: PLXS 3/27 “Response Code Op Code (RACP)”*

Item	Feature	Reference	Status
1	Null Operator	[1] 3.4.4–7	M

2.4 GATT requirements

Table 10: GATT Requirements

Item	Feature	Reference	Status	Inter-Layer Dependency
1	No longer used	N/A	N/A	N/A
2	GATT Server over LE	[1] 1.5	C.4	[2] GATT 1a/3
3	GATT Server over BR/EDR	[1] 1.5	C.5	[2] GATT 1a/4
4	Read Characteristic Value	[1] 1.4	M	[2] GATT 4/8
5	Write Characteristic Value	[1] 1.4	C.1	[2] GATT 4/14
6	Single Notification	[1] 1.4	C.2	[2] GATT 4/17
7	Indication	[1] 1.4	C.3	[2] GATT 4/18
8	Read Characteristic Descriptor	[1] 1.4	M	[2] GATT 4/19
9	Write Characteristic Descriptor	[1] 1.4	M	[2] GATT 4/21

- C.1: Mandatory IF PLXS 2/3 “Measurement Storage for Spot-check Measurement Support”, otherwise not defined.
- C.2: Mandatory IF PLXS 3/9 “PLX Continuous Measurement Characteristic”, otherwise not defined.
- C.3: Mandatory IF PLXS 3/2 “PLX Spot-check Measurement Characteristic” OR PLXS 3a/2 “PLX Features characteristic indication”, otherwise not defined.
- C.4: Mandatory IF PLXS 1/2 “Service supported over LE”, otherwise not defined.
- C.5: Mandatory IF PLXS 1/1 “Service supported over BR/EDR”, otherwise not defined.



2.5 SDP requirements

Table 11: SDP Requirements

Prerequisite: PLXS 1/1 "Service supported over BR/EDR"

Item	Feature	Reference	Status
1	SDP record present for PLXS	[1] 4	M
2-3	No longer used	N/A	N/A

Table 12: No longer used

3 References

- [1] Pulse Oximeter Service Specification, Version 1.0 or later
- [2] ICS Proforma for Generic Attribute Profile (GATT)
- [3] Pulse Oximeter Service Specification, Version 1.0.1

4 Revision history and acknowledgments

Revision History

Publication Number	Revision Number	Date	Comments
0	1.0.0	2015-07-21	Prepared for publication
	1.0.1r00	2017-09-14	TSE 9789: Revised conditional status for table 3 items 7 and 15 and adds new conditionals in Table 3.
1	1.0.1	2017-11-28	Approved by BTI. Prepared for TCRL 2017-2 publication.
	p2r00–r06	2021-02-21 – 2021-12-23	TSE 16765 (rating 4): Updated C.1 in Table 0. Added new Table 0a, Table 3a, Table 12, and new item PLXS 2/9 and C.2. Added reference for PLXS Specification v1.0.1 (E16248). Removed reference to Bluetooth Core Specification, as it is not used. Performed editorial work, including updating to the latest ICS template and aligning the copyright page with v2 of the DNMD.
2	p2	2022-01-25	Approved by BTI on 2022-01-06. Prepared for TCRL 2021-2 publication.
	p3r00–r01	2023-10-06 – 2023-12-06	TSE 23676 (rating 2): Resolved GAP, GATT, and SDP inter-layer dependencies. In Table 0, added new conditional C.1 and updated the existing C.1 (now C.2). In Table 0a, updated the reference for Item 1 and conditional C.1. Updated C.1 for Table 1. In Table 2, updated the Reference and Status values for Item 9, updated C.1, and deleted C.2. In Table 3, updated C.1–C.12. In Table 3a, updated C.1. In Table 10, marked Item 1 as no longer used; updated the Feature and ILD values for Item 2; updated the Feature, Status, and ILD values for Item 3; updated C.1–C.4; and added C.5. In Table 11, updated the prerequisite, deleted the ILD column, updated the Feature value for Item 1, and marked Items 2 and 3 as no longer used. Marked Table 12 as no longer used. Editorial edits to align with the latest ICS template, including updates to table titles and references. Deleted draft revision history comments prior to p0.
3	p3	2024-07-01	Approved by BTI on 2024-04-21. Prepared for TCRL 2024-1 publication.
	p3ed2r00– r01	2025-07-10 – 2025-07-15	TSE 27335 (rating 1): Updated the language in C.2 of Table 0. Updated the Status for PLXS 1/1 and PLXS 1/2, added conditions C.1 and C.2, and renumbered the previous C.1 as C.3. Updated the Feature in PLXS 10/6.
	p3 edition 2	2025-08-05	Approved by BTI on 2025-08-05. Prepared for edition 2 publication.

Publication Number	Revision Number	Date	Comments
	p4r00-r01	2025-12-04 – 2026-01-09	TSE 28169 (rating 1): Updated the conditions in the transport table to make sure the layer is excluded when the design is an implementation of the Core-Controller Configuration by adding "OR CORE 40/1 "Core-Controller"" to an already excluded transport based on Core Configuration support.
4	p4	2026-02-17	Approved by BTI on 2026-01-21. Prepared for TCRL pkg102 publication.

Acknowledgments

Name	Company
Jörg Brakensiek	Bluetooth SIG, Inc.
Ismail Mohamud	Bluetooth SIG, Inc.
Alicia Courtney	Broadcom
Jordan Hartmann	Nonin Medical, Inc.
Magnus Sommansson	Qualcomm Technologies International Inc.